



March 21, 2023

**ADDENDUM NUMBER 3  
TO FOR AERIALY DEPOSITED LEAD ASSESSMENT  
AND LEAD COMPLIANCE PLAN  
FOR THE AZUSA RIVER WILDERNESS PARK ENTRY DEVELOPMENTS PROJECT**

**GOVERNING BOARD**

**Herlinda Chico,**

Designee for Janice Hahn  
Los Angeles County Board of  
Supervisors, 4th District

**Sandra Croxton  
Vice Chair**

Designee for Kathryn Barger  
Los Angeles County Board of  
Supervisors, 5th District

**Vincent Chang**

Designee for Hilda Solis  
Los Angeles County Board of  
Supervisors, 1st District

**Vacant**

Designee for Holly Mitchell  
Los Angeles County Board of  
Supervisors, 2nd District

**Dan Arrighi,**

Rivers and Mountains  
Conservancy

**Roberto Uranga**

Rivers and Mountains  
Conservancy

**Denise Diaz**

Rivers and Mountains  
Conservancy

**EX OFFICIO MEMBER**

Carolina Hernandez  
Designee for Mark Pestrella,  
Director  
Los Angeles County  
Department of Public Works

**EXECUTIVE OFFICER**

Mark Stanley

On March 1, 2023, the Watershed Conservation Authority (WCA) released a Request for Proposals (RFP) for aerially deposited lead assessment and lead compliance plan for the Azusa River Wilderness Park Entry Developments Project.

Answers to questions received by March 21, 2023 are being issued as part of this Addendum.

- |            |  |
|------------|--|
| Q5         | Please advise if any of the scope of services requested will be to subject to prevailing wage requirements.  |
| <b>A5</b>  | <b>The requested services qualify as public works and are subject to prevailing wage requirements.</b>   |
| Q6         | Will all excavation along the road be to 10 feet below ground surface, allowing characterization of all soil from 0-10 ft as one waste stream?   |
| <b>A6</b>  | <b>Yes.</b>  |
| Q7         | Will the work require an encroachment permit?  |
| <b>A7</b>  | <b>Yes.</b>  |
| Q8         | Will the work require a traffic controller?  |
| <b>A8</b>  | <b>Yes.</b>  |
| Q9         | Will the work require a private utility locator?   |
| <b>A9</b>  | <b>Yes.</b>  |
| Q10        | Can the work be completed during normal working hours (M-F, 8:00 AM to 5:00 PM)?   |
| <b>A10</b> | <b>Yes, dependent on terms of encroachment permit with Caltrans. However, including a range or higher limit for labor outside normal working hours may be advisable in the event Caltrans imposes such a requirement. Please note if a range or higher limit are included to address potentially higher rates for labor after hours.</b> |

- Q11 Are there any access limitations for a direct-push drill rig?
- A11 There are no special access limitations in the work area beyond standard limitations that may be imposed by right of access through Caltrans.**
- Q12 Will groundwater be encountered within the maximum depth of the borings (10 feet below ground surface)?
- A12 No groundwater has been observed or would be expected at 10' below ground surface in the vicinity of work area.**